

From: dbofinger@kemron.com
Sent: 2/7/2012 12:23:27 PM

To: "Richard Fetzer" <Fetzer.Richard@epamail.epa.gov>

CC:

Subject:

Ex. 6 - Personal Privacy

Rich,

We have been checking the water level in the holding tank at this property daily and there has been no usage of water from this tank through Monday February 6th. Today when I checked the level of water in the tank it contained an estimated 20 gallons, since yesterday the level of the tank has dropped approximately 1,000 gallons. At this time I seen **Ex. 6 - Personal Privacy** tearing down a abandoned shed located by the **Ex. 6 - Personal Privacy** house. I approached **Ex. 6 - Personal Privacy** and made him aware of this water usage since yesterday and he replies that he is unaware of why there would be usage. I then suggested that the power to the pump system be turned off and that if possible that he checked the interior of the house and trailer for possible water leaks. **Ex. 6 - Personal Privacy** said to turn off the power and he would check for leaks.

At the current time, the power to the system at this property has been turned off and **Ex. 6 - Personal Privacy** is aware of this and the tank has been partially refilled with approximately 500 gallons of water in case **Ex. 6 - Personal Privacy** identifies the reason for the excessive water consumption and then turns the power to the pump back on.

Dave Bofinger
Response Manager
Kemron Environmental Services Inc
1359-A Ellsworth Industrial Blvd
Atlanta, GA 30318
e mail- dbofinger@Kemron.com
Cell phone- 404 725 3257
Phone-404 636 0928 Fax 404 636 7162
Visit us at www.kemron.com

Know Safety, No Accidents

P Before printing, think about ENVIRONMENTAL responsibility

The information contained in this email may be confidential and/or legally privileged. It has been sent for the sole use of the intended recipient(s). If the reader of this message is not an intended recipient, you are hereby notified that any unauthorized review, use, disclosure, dissemination, distribution, or copying of this communication, or any of its contents, is strictly prohibited. If you have received this communication in error, please reply to the sender and destroy all copies of the message. To contact us directly, send to postmaster@kemron.com. Thank you.